



February 28, 2024

The Corporation of the Municipality of Huron East
72 Main St. S
P.O. Box 610
Seaforth, ON
N0K 1W0

Attention: Brad McRoberts, CAO

**RE: Seaforth Well Supply System
2023 Annual Report**

Dear Brad,

Please find attached the 2023 Annual Operations Report for the Seaforth Water System, in accordance with Section 11(1) of O. Reg. 170/03. This report covers the period from January 1 to December 31 and meets the requirement of being prepared by February 29 of this year.

Please ensure that a copy of this report is given, without charge, to every person who requests a copy. In addition, please make certain that effective steps are taken to advise residents that copies of the report are available, and of how a copy can be obtained.

As per Schedule 22 of O. Reg. 170/03, please ensure that at least a copy of the Summary Report is given to the members of municipal council no later than March 31, 2024.

Finally, please ensure that a letter is sent to Jacobs verifying that this report has been received and accepted by Council.

If you have any questions regarding the report, we would be pleased to address them and you should contact the undersigned accordingly.

Sincerely,

Jacobs (OMI Canada Inc.)

A handwritten signature in black ink, appearing to read "Aaron Yungblut".

Aaron Yungblut

Project Manager/Overall Responsible Operator (ORO)
Huron East Project
226 921 5420

cc. B. Mills, Municipality of Huron East;

2023 ANNUAL REPORT FOR WATER SYSTEMS

Part 1 – ANNUAL REPORT (as required by O. Reg. 170/03, Section 11)

Drinking-Water System Number:	220001511
Drinking-Water System Name:	Seaforth Well Supply System
Drinking-Water System Owner:	The Corporation of the Municipality of Huron East
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1-December 31, 2023

Complete if your Category is Large Municipal Residential or Small Municipal Residential	Complete for all other Categories
Does your Drinking-Water System serve more than 10,000 people? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Number of Designated Facilities served: N/A
Is your annual report available to the public at no charge on a web site on the Internet? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Did you provide a copy of your annual report to all Designated Facilities you serve? <input type="checkbox"/> Yes <input type="checkbox"/> No
Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection. Town Office 72 Main St. S. Seaforth, ON	Number of Designated Facilities served: N/A
	Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? <input type="checkbox"/> Yes <input type="checkbox"/> No

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

N/A

Indicate how you notified system users that your annual report is available, and is free of charge.

<input checked="" type="checkbox"/> Public access/notice via the web	<input checked="" type="checkbox"/> Public access/notice via Government Office	<input type="checkbox"/> Public access/notice via a newspaper
<input type="checkbox"/> Public access/notice via Public Request	<input type="checkbox"/> Public access/notice via a Public Library	<input type="checkbox"/> Public access/notice via other method

Describe your Drinking Water System

As of mid-April 2009, the town of Seaforth draws its water supply from three groundwater wells. All wells are located at 40 Welsh St. The Welsh Street facility consists of an above ground pump house with three groundwater wells each located north of the pump house. TW1 (Test Well #1; but is to be considered to be a production well) is a 150mm diameter, 85m deep groundwater well located at 48m northwest of the new pump house. It is equipped with a submersible turbine pump

at 6.4L/s. PW 1 (Production Well #1) is a 300mm diameter, 105m deep drilled groundwater well located 43m northwest of the pump house. It is equipped with a variable speed submersible turbine pump rated at 35/Ls. PW 2 (Production Well #2) has the same dimensions as PW1 and is located 18m northwest of the pump house. It contains a variable speed submersible turbine pump rated at 40/Ls. Three vertical turbine high lift pumps (one rated at 26L/s and two rated at 44L/s at 48m TDH) convey the water to the distribution system. There is a 670 m³ underground reservoir located on site that provides contact time for the treated water. It also serves as backup emergency storage and fire protection if the water tower is offline. This facility is equipped with a 175 kW generator and automatic transfer switch to provide back up power.

Treatment for the Welsh St. wells consists of a chlorination system that includes two sodium hypochlorite metering pumps (one main and one backup) and one 200 L day tank for sodium hypochlorite. Sodium Silicate is also added to the system (three pumps available, 1 dedicated to each well) as well as a 200L day tank. A continuous online chlorine analyzer equipped with alarms monitor the chlorine residual in the treated water just prior to the point of entry into the distribution system.

Water in excess of demand in the distribution system is pumped to the elevated storage tank (water tower). When a predetermined level in the tower is reached, the distribution pump(s) shut down.

The 1930 m³ elevated storage tank was constructed in 1998 and is located at 85 Daly Street. The elevated tank water level cycles based on demand and provides emergency storage, fire protection and peak demand storage for the Seaforth water supply system.

The distribution system supplies water to the entire Town of Seaforth and the Village of Egmondville. The system is composed of cast iron, ductile iron and PVC watermain with 129 hydrants. There is 1 automatic blow-off, 9 manual blow-offs and 3 sample stations are connected throughout the distribution system. The elevated storage tank and the underground reservoir are used as a supplementary supply for emergencies.

Jacobs operates and maintains these drinking water facilities and water treatment processes while the Municipality of Huron East operates and maintains the distribution system with the exception of fire hydrant flushing, which is contracted to Jacobs.

List all water treatment chemicals used over this reporting period

12% Sodium hypochlorite solution
Sodium silicate

Please provide a brief description and a breakdown of monetary expenses incurred

-New VFD was installed for PW2 well pump

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre					
Incident Date	Parameter	Result	Units	Corrective Action	Corrective Action Date
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period					
	Number of Samples	Range of E.Coli Results (min #) - (max #)	Range of Total Coliform Results (min #) - (max #)	Number of HPC Samples	Range of HPC Results (min #) - (max #)
Raw (TW1)	50	0	0	N/A	-
Raw (PW1)	52	0	0	N/A	-
Raw (PW2)	52	0	0	N/A	-
Treated (40 Welsh)	52	0	0	52	<10-10
Distribution	208	0	0	104	<10-20

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report			
	Number of Grab Samples	Range of Results (min #) – (max #)	Units
Turbidity (TW1)	35	0.31-0.98	NTU
Turbidity (PW1)	50	0.24-0.85	NTU
Turbidity (PW2)	51	0.26-0.91	NTU
Chlorine (Tower)	8760	0.51-2.10	mg/L
Chlorine (40 Welsh)	8760	0.65-2.59	mg/L
Fluoride (If the DWS provides fluoridation)	n/a		

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument				
Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results (<MDL: Below Minimum Detection Limit) Note: Sodium + Fluoride sampling required every 60 months. Inorganic sampling required every 36 months.

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	April 13/21	0.9	ug/L	No
Arsenic	April 13/21	0.5	ug/L	No
Barium	April 13/21	33.1	ug/L	No
Boron	April 13/21	151	ug/L	No
Cadmium	April 13/21	0.037	ug/L	No
Chromium	April 13/21	0.24	ug/L	No
Haloacetic Acids (HAA) <i>Running Annual Average</i>	Q1 – Q4 2023	5.3	ug/L	No
Lead-sampling conducted by the Municipality of Huron East; see summary below				
Mercury	April 13/21	<MDL	ug/L	No
Selenium	April 13/21	0.07	ug/L	No
Sodium	April 2/19	43.7	mg/L	Yes
Uranium	April 13/21	8.15	ug/L	No
Fluoride	April 2/19	1.70	mg/L	Yes
Nitrite & Nitrate sampling required Quarterly				
Nitrite	Jan 10/23	0.003	mg/L	No
Nitrate	Jan 10/23	0.025	mg/L	No
Nitrite	April 11/23	0.003	mg/L	No
Nitrate	April 11/23	0.017	mg/L	No
Nitrite	July 25/23	0.003	mg/L	No
Nitrate	July 25/23	0.028	mg/L	No
Nitrite	Oct 17/23	0.003	mg/L	No
Nitrate	Oct 17/23	0.028	mg/L	No

Summary of Lead Results* Sampled by Municipal Staff

Sampling Period	Range of Results (µg/L)	Non-residential	Distribution	Adverse Incidents?
Dec-15-22-Apr-15-23	0.06-0.09	N/A	2	No
Jun-15-23-Oct-15-23	0.07-0.16	N/A	2	No

Summary of Organic parameters tested during this reporting period or the most recent sample results (<MDL: Below Minimum Detection Limit) Note: Organic sampling required every 36 months.

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	April 13/21	<MDL	ug/L	No
Atrazine	April 13/21	<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	April 13/21	<MDL	ug/L	No
Azinphos-methyl	April 13/21	<MDL	ug/L	No
Benzene	April 13/21	<MDL	ug/L	No
Benzo(a)pyrene	April 13/21	<MDL	ug/L	No
Bromoxynil	April 13/21	<MDL	ug/L	No
Carbaryl	April 13/21	<MDL	ug/L	No
Carbofuran	April 13/21	<MDL	ug/L	No
Carbon Tetrachloride	April 13/21	<MDL	ug/L	No
Chlorpyrifos	April 13/21	<MDL	ug/L	No

Summary of Organic parameters tested during this reporting period or the most recent sample results (<MDL: Below Minimum Detection Limit) Note: Organic sampling required every 36 months



Diazinon	April 13/21	<MDL	ug/L	No
Dicamba	April 13/21	<MDL	ug/L	No
1,2-Dichlorobenzene	April 13/21	<MDL	ug/L	No
1,4-Dichlorobenzene	April 13/21	<MDL	ug/L	No
1,2-Dichloroethane	April 13/21	<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	April 13/21	<MDL	ug/L	No
Dichloromethane	April 13/21	<MDL	ug/L	No
2-4 Dichlorophenol	April 13/21	<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	April 13/21	<MDL	ug/L	No
Diclofop-methyl	April 13/21	<MDL	ug/L	No
Dimethoate	April 13/21	<MDL	ug/L	No
Diquat	April 13/21	<MDL	ug/L	No
Diuron	April 13/21	<MDL	ug/L	No
Glyphosate	April 13/21	<MDL	ug/L	No
Desethyl atrazine	April 13/21	<MDL	ug/L	No
Malathion	April 13/21	<MDL	ug/L	No
MCPA	April 13/21	<MDL	mg/L	No
Metolachlor	April 13/21	<MDL	ug/L	No
Metribuzin	April 13/21	<MDL	ug/L	No
Monochlorobenzene	April 13/21	<MDL	ug/L	No
Paraquat	April 13/21	<MDL	ug/L	No
Polychlorinated Biphenyls (PCBs)	April 13/21	<MDL	ug/L	No
Pentachlorophenol	April 13/21	<MDL	ug/L	No
Phorate	April 13/21	<MDL	ug/L	No
Picloram	April 13/21	<MDL	ug/L	No
Prometryne	April 13/21	<MDL	ug/L	No
Simazine	April 13/21	<MDL	ug/L	No
Trihalomethanes (THM's) <i>Running Annual Average</i>	Q1-Q4 2023	24.8	µg/L	No
Terbufos	April 13/21	<MDL	ug/L	No
Tetrachloroethylene	April 13/21	<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	April 13/21	<MDL	ug/L	No
Triallate	April 13/21	<MDL	ug/L	No
Trichloroethylene	April 13/21	<MDL	ug/L	No
2,4,6-Trichlorophenol	April 13/21	<MDL	ug/L	No
Trifluralin	April 13/21	<MDL	ug/L	No
Vinyl Chloride	April 13/21	<MDL	ug/L	No

Parameter	Sample Date	Result Value	ODWQS Limit	Unit of Measure
Sodium	April 2/19	43.7	20.0	mg/L
Fluoride	April 2/19	1.70	1.50	mg/L

Part 2 – SUMMARY REPORT (as required by O. Reg 170/03, Schedule 22)

Non – Compliance with Legislations, Regulations, Approvals & Orders		
During this period, the Facility was operated in full compliance with the Act, the regulations and the Facility's approval, save and except for the following:		
Requirement	Duration of Failure	Measures to Correct the Failure
N/A (Received 100% Inspection Rating).		

System Capability Assessment							
Comparison of Flow Rates (m ³ /d):							
Month	Avg. Flow TW1	Max. Flow TW1	Avg. Flow PW1	Max. Flow PW1	Avg. Flow PW2	Max. Flow PW2	Max Daily Total (PW1+PW2+TW1)
January	58	92	370	425	438	496	943
February	58	70	372	496	433	509	1158
March	52	71	345	380	425	481	936
April	43	48	345	377	424	471	1240
May	67	136	481	827	609	1000	1731
June	89	146	473	935	628	1053	1429
July	65	130	446	677	532	755	1570
August	36	84	500	1031	417	647	1127
September	1.79	54	461	572	464	566	1116
October	0	0	474	813	483	837	1537
November	0	0	474	1052	462	919	2082
December	0	0	429	488	417	482	946
AVERAGE	39	-	431	-	478	-	-
MAXIMUM	89	146	500	1031	628	1053	2082
Total Rated CAPACITY	3139	3139	3139	3139	3139	3139	3139
%CAPACITY	1.24	4.65	13.7	32.8	15.2	33.5	66.3
Total Annual Flow (TW1+PW1+PW2): 353 137 m ³							