



BRUCEFIELD DRINKING WATER SYSTEM

WDS # 220007604

2025 ANNUAL SUMMARY REPORT OF OPERATIONS

Managed, Operated and Maintained by:

Jacobs

Table of Contents

| | |
|---|----|
| 1.0 INTRODUCTION AND BACKGROUND | 3 |
| 2.0 DESCRIPTION OF WATER SYSTEM | 3 |
| 3.0 SUMMARY OF WATER QUALITY MONITORING | 4 |
| 3.1 Water Treatment Equipment Operation and Monitoring | 4 |
| 3.2 Microbiological Sampling | 5 |
| 3.3 Chemical Sampling and Testing | 6 |
| 3.3.1 Schedule 13 Sampling (Nitrate, Nitrite, THMs, HAAs) | 6 |
| 3.3.2 Schedule 15.1 Sampling (Lead) | 7 |
| 3.3.3 Schedule 23 and 24 Sampling (Organics and Inorganics) | 7 |
| 4.0 WATER AND CHEMICAL USE | 9 |
| 4.1 Chemical Usage | 9 |
| 4.2 Summary of Flow Rates, Annual Volumes and Capacities | 10 |
| 5.0 IMPROVEMENTS, ROUTINE AND PREVENTATIVE MAINTENANCE | 10 |
| 6.0 MECP INSPECTIONS AND REGULATORY ISSUES | 10 |
| 7.0 WELL LEVELS (PTTW) | 11 |

1.0 INTRODUCTION AND BACKGROUND

The purpose of the 2025 Annual Report is to document the operation and maintenance data for the Brucefield Drinking Water System for review by the Ministry of the Environment, Conservation and Parks (MECP) in accordance with O. Reg 170/03. This report covers the period from January 1, 2025, to December 31, 2025. A copy of this report is to be made available on the Municipalities website and/or provided to interested parties upon request.

2.0 DESCRIPTION OF WATER SYSTEM

A summary of the Brucefield Drinking Water System is outlined below:

| | |
|--------------------------------------|----------------------------------|
| Drinking Water System Number: | 220007604 |
| Drinking Water System Name: | Brucefield Drinking Water System |
| Drinking Water System Owner: | Municipality of Huron East |
| Drinking Water System Category: | Small Municipal Residential |
| Daily Maximum Water Supply Capacity: | 270 m ³ /day |
| Population: | 175 |
| 2025 Average Daily Demand: | 56.97 m ³ /day |
| 2025 Peak Day Demand: | 105 m ³ |

The well site is detailed as follows:

Brucefield Well Site #1

| | |
|-------------------------|--|
| • Water Source | Groundwater, Non-GUDI, Limited Ground Water |
| • Number of Wells | 1 |
| • Depth of Wells | 88.392 m |
| • Size of Casing | 200 mm |
| • Production Capacity | 270 m ³ /day |
| • Well Pumps | 1 (318 L/min) |
| • Disinfection | UV (min dose 40 mJ/cm ²) Sodium Hypochlorite (12%) |
| • Pressure Tanks | 4 (540L each) |
| • Permit To Take Water: | P-300-1617138585 Expires June 11, 2032 |

Well located at the intersection of Highway 4 and County Road 3 is 290 feet deep with a 200 mm diameter steel casing and a submersible pump rated for 318 L/min (458 m³/ day). The aquifer is broken limestone with a clay overburden. The well head is located outside the well house, near the doorway.

The well pump is started and stopped by the PLC provided the power is on for 20 seconds the pump will start at 220 kpa after 5 seconds and stop at 370 kpa after 5 seconds. If the PLC is off the pump will start and stop off the pressure switch at approximately 36 psi to 52 psi (245 – 354 kpa). There is a Rosemont 1151 Pressure Transducer on the outlet line from the building which is linked to the SCADA monitoring and alarm system.

Primary disinfection is achieved by passing the raw water through Trojan UV Swift reactors at a minimum dosage of 40 mJ/cm² at 254 nm and peak flow rate of 7 L/s. Based on the characteristics of

the water source and the peak flow rate this translates to a minimum intensity of 27.1 W/m². If the reactor intensity drops below this point an alarm is signalled.

Secondary disinfection is achieved by injection of 12% sodium hypochlorite solution immediately after the UV reactors. Contact and mixing occurs in the piping from the ejection point and throughout the distribution system. No contact or mixing chamber is used.

3.0 SUMMARY OF WATER QUALITY MONITORING

3.1 Water Treatment Equipment Operation and Monitoring

One (1) raw water sample is collected monthly from the well and analyzed inhouse for Turbidity and measured in Nephelometric Turbidity Units (NTU) in accordance with the Permit to Take Water (PTTW). For the reporting year a total of 16 samples were collected with all analysis within normal operating range for the well. A summary of the results can be found in table 1 below.

Table 1 – Well #1 Raw Turbidity

| Month | Raw Water | | |
|---------------|-----------|---------------|-------------|
| | # Samples | Average (NTU) | Max (NTU) |
| Jan | 3 | 0.49 | 0.57 |
| Feb | 1 | 0.45 | 0.45 |
| Mar | 1 | 0.47 | 0.47 |
| Apr | 1 | 0.43 | 0.43 |
| May | 1 | 0.38 | 0.38 |
| Jun | 3 | 0.51 | 0.58 |
| Jul | 1 | 0.31 | 0.31 |
| Aug | 1 | 0.55 | 0.55 |
| Sept | 1 | 0.60 | 0.60 |
| Oct | 1 | 0.40 | 0.40 |
| Nov | 1 | 0.41 | 0.41 |
| Dec | 1 | 0.42 | 0.42 |
| Yearly | 16 | 0.45 | 0.60 |

Treated and distribution water chlorine residuals are measured using continuous online analyzers which records data at 5-minute intervals as per the requirements of O. Reg 170/03. The regulations designate that a value of 8760 be used for number of samples when utilizing continuous monitors. A summary of the results can be found in table 2 below and were all within normal operating ranges. An additional 253 grab samples were collected in conjunction with the weekly bacteriological sample and tested for free chlorine within the distribution network and analyzed using a handheld colorimeter.

Table 2 – Well Treated and Distribution Chlorine Residual Averages

| Month | Well #1 Treated Online | Distribution Network Grab |
|----------------|------------------------|---------------------------|
| Jan | 1.60 | 1.38 |
| Feb | 1.59 | 1.38 |
| Mar | 1.61 | 1.45 |
| Apr | 1.52 | 1.38 |
| May | 1.51 | 1.39 |
| Jun | 1.55 | 1.43 |
| Jul | 1.55 | 1.41 |
| Aug | 1.54 | 1.39 |
| Sept | 1.47 | 1.40 |
| Oct | 1.58 | 1.38 |
| Nov | 1.65 | 1.47 |
| Dec | 1.56 | 1.31 |
| # of Samples | 8760 | 253 |
| Annual Average | 1.56 | 1.40 |
| Annual Min | 0 | 0.94 |
| Annual Max | 2.02 | 1.68 |

*Annual Minimum and Maximum values represent all 5-minute data for the year, and captures data while cleaning sensors, flushing units, performing calibrations and power outages.

3.2 Microbiological Sampling and Testing

One (1) raw water sample is collected from the well monthly and send out for analysis of Total Coliforms and E. Coli in accordance with Schedule 11 of O. Reg 170/03. A total of 13 samples were collected in the reporting year for the Brucefield WDS. All results indicate the well is in good health. A summary of the results can be found in table 3 below.

Table 3 – Raw Well #1 Microbiological Results

| Month | Total Coliforms | | | E. Coli | | |
|--------------|-----------------|---------------|---------------|-----------|---------------|---------------|
| | # Samples | # Samples "0" | # Samples ≥ 1 | # Samples | # Samples "0" | # Samples ≥ 1 |
| Jan | 2 | 2 | 0 | 2 | 2 | 0 |
| Feb | 1 | 1 | 0 | 1 | 1 | 0 |
| Mar | 1 | 1 | 0 | 1 | 1 | 0 |
| Apr | 1 | 1 | 0 | 1 | 1 | 0 |
| May | 1 | 1 | 0 | 1 | 1 | 0 |
| Jun | 1 | 1 | 0 | 1 | 1 | 0 |
| Jul | 1 | 1 | 0 | 1 | 1 | 0 |
| Aug | 1 | 1 | 0 | 1 | 1 | 0 |
| Sept | 1 | 1 | 0 | 1 | 1 | 0 |
| Oct | 1 | 1 | 0 | 1 | 1 | 0 |
| Nov | 1 | 1 | 0 | 1 | 1 | 0 |
| Dec | 1 | 1 | 0 | 1 | 1 | 0 |
| TOTAL | 13 | 13 | 0 | 13 | 13 | 0 |

Currently one (1) distribution sample is collected weekly and sent out for analysis of Total Coliforms, E. Coli and HPC (Heterotrophic Plate Count) in accordance with Schedule 11 of O. Reg 170/03. A total of 52 samples were collected in the reporting year. A summary of the results can be found in table 4 below.

Table 4 – Distribution System Microbiological Results

| Month | Total Coliforms | | | E. Coli | | | HPC | |
|--------------|-----------------|---------------|---------------|-----------|---------------|---------------|-----------|----------------|
| | # Samples | # Samples "0" | # Samples ≥ 1 | # Samples | # Samples "0" | # Samples ≥ 1 | # Samples | # Samples > 10 |
| Jan | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 0 |
| Feb | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 0 |
| Mar | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 0 |
| Apr | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 0 |
| May | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 1 |
| Jun | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 1 |
| Jul | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 0 |
| Aug | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 0 |
| Sept | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 0 |
| Oct | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 1 |
| Nov | 4 | 4 | 0 | 4 | 4 | 0 | 4 | 0 |
| Dec | 5 | 5 | 0 | 5 | 5 | 0 | 5 | 0 |
| TOTAL | 52 | 52 | 0 | 52 | 52 | 0 | 52 | 3 |

3.3 Chemical Sampling and Testing

3.3.1 – Schedule 13 Sampling

One (1) treated water sample is taken from the well quarterly in accordance with Schedule 13 and analyzed for Nitrates and Nitrites. One (1) distribution sample is also collected quarterly in accordance with Schedule 13 and analyzed for HAAs (Haloacetic Acids). The Brucefield WDS is currently on a Reduced Sampling Program for Trihalomethanes (THMs) with the next sample to be collected only during quarter 1 of 2026. The samples collected during the 2025 calendar year were collected Apr, Jul and Oct. The results can be found in table 9 below.

Table 5 – Nitrate, Nitrite, THM and HAA Results

| Month | Well #1 | | Distribution | |
|----------------|----------------|----------------|--------------|-------------|
| | Nitrate (mg/L) | Nitrite (mg/L) | THMs (ug/L) | HAAs (ug/L) |
| Jan | 0.733 | 0.003 <MDL | - | 5.3 <MDL |
| Apr | 0.735 | 0.003 <MDL | 4.5 | 5.3 <MDL |
| Jul | 0.754 | 0.003 <MDL | 5.5 | 5.3 <MDL |
| Oct | 0.753 | 0.003 <MDL | 5.8 | 5.3 <MDL |
| Average | 0.744 | 0.003 | 5.27 | 5.30 |
| MAC | 10 | 1 | 100 | 80 |

*MDL- Minimum Detection Limit

One (1) treated water sample is collected from the well and sent out Sodium / Fluoride analysis every 60 months in accordance with Schedule 13, S.8 / 9. The most recent sample was collected October 17, 2023, and can be found in table 6 below. The next samples will be collected in October 2028.

Table 6 – Sodium and Fluoride Results

| Parameter | Treated Well 1 | MAC |
|-----------|----------------|-----|
| Sodium | 10.4 | 20 |
| Fluoride | 1.13 | 1.5 |

**MAC - Maximum Allowable Concentration*

3.3.2 – Schedule 15.1 Sampling (Lead)

One (1) distribution water sample is collected per sample season and sent out for Lead analysis in accordance with Schedule 15.1 of O. Reg 170/03. Samples were collected April 9th and October 3rd during the reporting year. All results were under the Maximum Allowable Concentration (MAC) for Lead in the distribution system. A summary of results can be found in table 7 below.

Table 7 – Lead and Alkalinity Results

| Season | Alkalinity (mg/L) | pH | Lead (ug/L) |
|------------|-------------------|------|-------------|
| Dec - Apr | 245 | 7.66 | 0.53 |
| Jun - Oct | 251 | 7.64 | 0.34 |
| MAC | | | 10 |

**MAC - Maximum Allowable Concentration*

3.3.3 – Schedule 23 and 24 (Inorganic and Organic) Parameters

One (1) treated water sample is taken from each well every 60 months in accordance with Schedule 13 and sent out for Schedule 23 and 24 parameter analysis. The most recent sample was collected April 13, 2021. The results were all within regulatory compliance and can be found in tables 8 and 9 below.

Table 8 – Schedule 23 Inorganic Sample Results (Apr 13, 2021)

| Parameter | Treated Well 1 | MAC |
|-----------|----------------|------|
| Antimony | 0.90 | 6 |
| Arsenic | 0.20 | 10 |
| Barium | 227 | 1000 |
| Boron | 21 | 5000 |
| Cadmium | 0.011 | 5 |
| Chromium | 0.24 | 50 |
| Mercury | 0.01 <MDL | 1 |

| | | |
|----------|------|----|
| Selenium | 0.33 | 50 |
| Uranium | 1.90 | 20 |

*MDL - Minimum Detection Limit

*MAC - Maximum Allowable Concentration

Table 9 – Schedule 24 Organic Sample Results (Apr 13, 2021)

| Parameter | Treated Well 1 | MAC |
|------------------------------------|----------------|------|
| Benzene | 0.32 <MDL | 1 |
| Carbon Tetrachloride | 0.17 <MDL | 2 |
| 1,2-Dichlorobenzene | 0.41 <MDL | 200 |
| 1,4-Dichlorobenzene | 0.36 <MDL | 5 |
| 1,1-Dichloroethylene | 0.33 <MDL | 14 |
| 1,2-Dichloroethane | 0.35 <MDL | 5 |
| Dichloromethane | 0.35 <MDL | 50 |
| Monochlorobenzene | 0.3 <MDL | 80 |
| Tetrachloroethylene | 0.35 <MDL | 10 |
| Trichloroethylene | 0.44 <MDL | 5 |
| Vinyl Chloride | 0.17 <MDL | 1 |
| Diquat | 1 <MDL | 70 |
| Paraquat | 1 <MDL | 10 |
| Glyphosate | 1 <MDL | 280 |
| Polychlorinated Byphenyls | 0.04 <MDL | 3 |
| Benzo(a)pyrene | 0.004 <MDL | 0.01 |
| Alachlor | 0.02 <MDL | 5 |
| Atrazine+N-dealkylated metabolites | 0.01 <MDL | 5 |
| Atrazine | 0.01 <MDL | - |
| Desethyl Atrazine | 0.01 <MDL | - |
| Azinphos-methyl | 0.05 <MDL | 20 |
| Carbaryl | 0.05 <MDL | 90 |
| Carbofuran | 0.01 <MDL | 90 |
| Chlorpyrifos | 0.02 <MDL | 90 |
| Diazinon | 0.02 <MDL | 20 |
| Dimethoate | 0.06 <MDL | 20 |
| Diuron | 0.03 <MDL | 150 |
| Malathion | 0.02 <MDL | 190 |
| Metolachlor | 0.01 <MDL | 50 |
| Metribuzin | 0.02 <MDL | 80 |
| Phorate | 0.01 <MDL | 2 |
| Prometryne | 0.03 <MDL | 1 |

| | | |
|--------------------------------|--------------|-----|
| Simazine | 0.01 <MDL | 10 |
| Terbufos | 0.01 <MDL | 1 |
| Triallate | 0.01 <MDL | 230 |
| Trifluralin | 0.02 <MDL | 45 |
| 2,4-Dichlorophenoxyacetic acid | 0.19 <MDL | 100 |
| Bromoxynil | 0.33 <MDL | 5 |
| Dicamba | 0.2 <MDL | 120 |
| Diclofop-methyl | 0.4 <MDL | 9 |
| MCPA (mg/L) | 0.00012 <MDL | 0.1 |
| Picloram | 1 <MDL | 190 |
| 2,4-Dichlorophenol | 0.15 <MDL | 900 |
| 2,4,6-Trichlorophenol | 0.25 <MDL | 5 |
| 2,3,4,6-Tetrachlorophenol | 0.20 <MDL | 100 |
| Pentachlorophenol | 0.15 <MDL | 60 |

***MDL - Minimum Detection Limit**

***MAC – Maximum Allowable Concentration**

4.0 WATER AND CHEMICAL USE

4.1 Chemical Usage

As per the Municipal Drinking Water License, all chemicals and materials used in the operation of a drinking water system shall meet all applicable standards set by both the American Water Works Association (AWWA) and the American National Standards Institute (ANSI) safety criteria stands NSF/60, NSF/61, and NSF/372.

Sodium Hypochlorite 12% (NaOCl) is used as a secondary disinfectant for the treated well water and provides a residual within the distribution system. A total of chemicals used can be found below in table 10.

Table 10 – Chemical Use and Average Dosage

| Month | Well #1 | |
|--------|--------------------|----------------------|
| | Chlorine Used L | Average Dose mg/L |
| Jan | 20 | 1.36 |
| Feb | 20 | 1.39 |
| Mar | 40 | 2.55 |
| Apr | 35 | 2.24 |
| May | 20 | 1.14 |
| Jun | 35 | 1.83 |
| Jul | 40 | 1.97 |
| Aug | 38 | 1.89 |
| Sept | 22 | 1.28 |
| Oct | 19 | 1.08 |
| Nov | 20 | 1.16 |
| Dec | 20 | 1.07 |
| Yearly | 329 | 1.58 |

4.2 Summary of Flow Rates, Annual Volumes and Capacities

A summary of water supplied to the Brucefield Water Distribution System in 2025 can be found in table 11 below. All volumes recorded are taken from the SCADA system and the daily operations printouts.

Table 11 – Well Flow Rates and Capacities

| Month | Well #1 (Rating 270 m3/day) | | | | |
|--------|-----------------------------|---------------|--------------|------------|--------------|
| | Total Flow | Daily Average | % Capacity | Daily Max | % Capacity |
| Jan | 1468 | 47.40 | 17.56 | 54 | 20.00 |
| Feb | 1438 | 51.36 | 19.02 | 62 | 22.96 |
| Mar | 1566 | 50.52 | 18.71 | 58 | 21.48 |
| Apr | 1564 | 52.13 | 19.31 | 95 | 35.19 |
| May | 1755 | 56.61 | 20.97 | 83 | 30.74 |
| Jun | 1913 | 63.77 | 23.62 | 79 | 29.26 |
| Jul | 2027 | 65.39 | 24.22 | 83 | 30.74 |
| Aug | 2006 | 64.71 | 23.97 | 105 | 38.89 |
| Sept | 1724 | 57.47 | 21.29 | 77 | 28.52 |
| Oct | 1766 | 56.97 | 21.10 | 95 | 35.19 |
| Nov | 1719 | 57.30 | 21.22 | 66 | 24.44 |
| Dec | 1862 | 60.06 | 22.24 | 67 | 24.81 |
| Yearly | 20808 | 56.97 | 21.10 | 105 | 38.89 |

5.0 IMPROVEMENTS TO SYSTEM AND ROUTINE / PREVENTATIVE MAINTENANCE

A Computerize Maintenance Management System (CMMS) is utilized to predict and track regular maintenance tasks associated with the Water Treatment and Distribution System in conjunction with the Municipalities Maintenance Management System. It is noted that Jacobs is the Operating Authority and deals directly with the Water Treatment and Point of Entry Systems, while the Municipality operates and maintains the distribution system.

The Operating Authority and the Municipality work together to complete all distribution flushing twice a year, spring and fall. It is noted that flow is maintained at each distribution flushing point until a free chlorine residual of 1.00 mg/L and attempt to achieve a turbidity of less than 1 NTU to ensure the overall health of the distribution system is maintained.

6.0 MINISTRY INSPECTION AND REGULATORY ISSUES

The MECP was onsite to complete its annual regulatory inspection on September 11th, 2025. A final report was issued by the MECP inspector October 30th, 2025. A final inspection rating of 100% was issued.

7.0 WELL LEVELS

As per the Permit to Take Water (PTTW), each production well is to have a static and dynamic depth measurement taken monthly at a minimum. This helps track the wells capacity to continue to be a production well and ensures the overall integrity of the water source. For the Brucefield WDS, measurements are taken and recorded as depth from the top of the well using a sounding probe. Static levels should be collected when the well has been off for a length of time. Dynamic levels are taken while the well in is operation between the middle of end of a run cycle. A summary of collected data can be found in table 18 below.

Table 12 – Static and Dynamic Well Depths

| Month | Well #1 | |
|-------|--------------|---------------|
| | Static (ft.) | Dynamic (ft.) |
| Jan | 241 | 242 |
| Feb | 242 | 243 |
| Mar | 243 | 244 |
| Apr | 243 | 245 |
| May | 243 | 244 |
| Jun | 241 | 243 |
| Jul | 242 | 242 |
| Aug | 241 | 242 |
| Sept | 243 | 241 |
| Oct | 243 | 242 |
| Nov | 243 | 242 |
| Dec | 242 | 243 |

ANNUAL REPORT

| | |
|--|--|
| Drinking-Water System Number: | 220007604 |
| Drinking-Water System Name: | Brucefield Well Supply System |
| Drinking-Water System Owner: | The Corporation of the Municipality of Huron East |
| Drinking-Water System Category: | Small Municipal Residential |
| Period being reported: | Jan 1st – Dec 31st, 2025 |

| | |
|---|---|
| <p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>Municipality of Huron East Town Office 72 Main St. S Box 610 Seaforth, ON N0K 1W0</p> </div> | <p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; padding: 2px; width: 100px; margin: 5px auto;">n/a</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; padding: 2px; width: 100px; margin: 5px auto;">n/a</div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p> |
|---|---|

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

| Drinking Water System Name | Drinking Water System Number |
|-----------------------------------|-------------------------------------|
| N/A | N/A |

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No []

Indicate how you notified system users that your annual report is available and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method

Describe your Drinking-Water System

Water Distribution System Class 2 with Limited Ground Water

The production well is located at the intersection of Highway 4 and County Road 3. The well is 88.39m deep with a 200mm steel casing. The well is equipped with a submersible pump rated for 318 L/min. The Well House contains four (4) 540L bladder type pressure tanks and provides both primary and secondary disinfection by UV disinfection and use of 12% sodium hypochlorite. The Well House is equipped with a 25-kW diesel generator and automatic transfer switch to provide backup power in the case of utility power loss.

List all water treatment chemicals used over this reporting period

12% Sodium Hypochlorite Solution

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|-----------|--------|-----------------|-------------------|------------------------|
| | | | | | |

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|---------------------|-------------------|--|---|-----------------------|--------------------------------------|
| Raw Well #1 | 13 | 0 | 0 | N/A | N/A |
| Distribution | 52 | 0 | 0 | 52 | <10 – 60 |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) | Unit of Measure |
|---------------------------------|------------------------|----------------------------------|-----------------|
| Turbidity Raw Well #1 | 16 | 0.31 – 0.60 | NTU |
| Treated Chlorine Well #1 | 8760 | 0 – 2.02 | mg/l |

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of Inorganic parameters tested during this reporting period recent sample results

| (<MDL: Below Minimum Detection Limit) | | | | |
|--|---------------------------|----------------------|-----------------|------------|
| Note: Sodium + Fluoride sampling required every 60 months. Inorganic sampling required every 60 months. | | | | |
| Parameter | Sample Date | Result Value Well #1 | Unit of Measure | Exceedance |
| Antimony | Apr 13/21 | 0.90 | ug/L | No |
| Arsenic | Apr 13/21 | 0.2 | ug/L | No |
| Barium | Apr 13/21 | 227 | ug/L | No |
| Boron | Apr 13/21 | 21 | ug/L | No |
| Cadmium | Apr 13/21 | 0.011 | ug/L | No |
| Chromium | Apr 13/21 | 0.24 | ug/L | No |
| Mercury | Apr 13/21 | <0.01MDL | ug/L | No |
| Selenium | Apr 13/21 | 0.33 | ug/L | No |
| Uranium | Apr 13/21 | 1.90 | ug/L | No |
| Sodium | Oct 17/23 | 10.4 | mg/L | No |
| Fluoride | Oct 17/23 | 1.13 | mg/L | No |
| Haloacetic Acids (HAA) (Running Annual Ave) | Q1 – Q4 2025 Distribution | 5.3 | Ug/L | No |

| | | | | |
|---|---------------------------|------------|------|----|
| Trihalomethanes (THM's) (Running Annual Ave) | Q2 – Q4 (Distribution) | 5.27 | Ug/L | No |
| Nitrite & Nitrate sampling required Quarterly | | | | |
| Nitrite | Jan 2025 | <0.003 MDL | ug/L | No |
| Nitrate | Jan 2025 | 0.733 | ug/L | No |
| Nitrite | Apr 2025 | <0.003 MDL | ug/L | No |
| Nitrate | Apr 2025 | 0.735 | ug/L | No |
| Nitrite | July 2025 | <0.003 MDL | ug/L | No |
| Nitrate | July 2025 | 0.754 | ug/L | No |
| Nitrite | Oct 2025 | <0.003 MDL | ug/L | No |
| Nitrate | Oct 2025 | 0.753 | ug/L | No |

Summary of lead testing under Schedule 15.1 during this reporting period

(Applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

| Sampling Period | Number of Samples | Range of Lead Results (min#) – (max #) | Unit of Measure | Number of Exceedances |
|--|-------------------|--|-----------------|-----------------------|
| Dec/24 – Apr/25 | 1 | 0.53 | ug/L | No |
| Jun/25 – Oct/25 | 1 | 0.34 | ug/L | No |
| Lead Sampling Conducted by Municipality | | | | |

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| (<MDL: Below Minimum Detection Limit) Note: Sampling required every 60 months. | | | | |
|--|-------------|----------------------|-----------------|------------|
| Parameter | Sample Date | Result Value Well #1 | Unit of Measure | Exceedance |
| Alachlor | Apr 13/21 | <MDL | ug/L | No |
| Atrazine + N-dealkylated metabolites | Apr 13/21 | <MDL | ug/L | No |
| Atrazine | Apr 13/21 | <MDL | ug/L | No |
| Azinphos-methyl | Apr 13/21 | <MDL | ug/L | No |
| Benzene | Apr 13/21 | <MDL | ug/L | No |
| Benzo(a)pyrene | Apr 13/21 | <MDL | ug/L | No |
| Bromoxynil | Apr 13/21 | <MDL | ug/L | No |
| Carbaryl | Apr 13/21 | <MDL | ug/L | No |
| Carbofuran | Apr 13/21 | <MDL | ug/L | No |
| Carbon Tetrachloride | Apr 13/21 | <MDL | ug/L | No |

| | | | | |
|---------------------------------------|-----------|------|------|----|
| Chlorpyrifos | Apr 13/21 | <MDL | ug/L | No |
| Desethyl atrazine | Apr 13/21 | <MDL | ug/L | No |
| Diazinon | Apr 13/21 | <MDL | ug/L | No |
| Dicamba | Apr 13/21 | <MDL | ug/L | No |
| 1,2-Dichlorobenzene | Apr 13/21 | <MDL | ug/L | No |
| 1,4-Dichlorobenzene | Apr 13/21 | <MDL | ug/L | No |
| 1,2-Dichloroethane | Apr 13/21 | <MDL | ug/L | No |
| 1,1-Dichloroethylene (vinylidene) | Apr 13/21 | <MDL | ug/L | No |
| Dichloromethane | Apr 13/21 | <MDL | ug/L | No |
| 2-4 Dichlorophenol | Apr 13/21 | <MDL | ug/L | No |
| 2,4-Dichlorophenoxy acetic acid (2,4- | Apr 13/21 | <MDL | ug/L | No |
| Diclofop-methyl | Apr 13/21 | <MDL | ug/L | No |
| Dimethoate | Apr 13/21 | <MDL | ug/L | No |
| Diquat | Apr 13/21 | <MDL | ug/L | No |
| Diuron | Apr 13/21 | <MDL | ug/L | No |
| Glyphosate | Apr 13/21 | <MDL | ug/L | No |
| Malathion | Apr 13/21 | <MDL | ug/L | No |
| MCPA | Apr 13/21 | <MDL | ug/L | No |
| Metolachlor | Apr 13/21 | <MDL | ug/L | No |
| Metribuzin | Apr 13/21 | <MDL | ug/L | No |
| Monochlorobenzene | Apr 13/21 | <MDL | ug/L | No |
| Paraquat | Apr 13/21 | <MDL | ug/L | No |
| Pentachlorophenol | Apr 13/21 | <MDL | ug/L | No |
| Phorate | Apr 13/21 | <MDL | ug/L | No |
| Picloram | Apr 13/21 | <MDL | ug/L | No |
| Polychlorinated Biphenyls(PCB's) | Apr 13/21 | <MDL | ug/L | No |
| Prometryne | Apr 13/21 | <MDL | ug/L | No |
| Simazine | Apr 13/21 | <MDL | ug/L | No |
| Terbufos | Apr 13/21 | <MDL | ug/L | No |
| Tetrachloroethylene | Apr 13/21 | <MDL | ug/L | No |
| 2,3,4,6-Tetrachlorophenol | Apr 13/21 | <MDL | ug/L | No |
| Triallate | Apr 13/21 | <MDL | ug/L | No |
| Trichloroethylene | Apr 13/21 | <MDL | ug/L | No |
| 2,4,6-Trichlorophenol | Apr 13/21 | <MDL | ug/L | No |
| Trifluralin | Apr 13/21 | <MDL | ug/L | No |
| Vinyl Chloride | Apr 13/21 | <MDL | ug/L | No |

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

| Parameter | Result Value | Unit of Measure | Date of Sample | ODWQS limit |
|-----------|--------------|-----------------|----------------|-------------|
| | | | | |
| | | | | |